

Development Details				Hardness					Water Quality	
NAV Development Site Reference	NAV Development Site Water Supply Zone Name	Location	Incumbent Water Supplier	Calcium Carbonate (mg/L)	Calcium (mg/L)	Degrees Clark (°C)	Degrees French (°F)	Degrees German (°F)	Hardness Classification	Full Water Quality Report from Incumbent
ZAWIN001	Abbots Vale WSZ	Rushbrooke Lane North, Bury St Edmunds, IP33 2BS	Anglian Water Services Limited	392.7mg/l	157.08mg/l	27.332 °C	39.27°F	22.305°dH	Very Hard	<a href="#">Abbots Vale Water Quality Report</a>
ZAWIN002	Lenham WSZ	Old Ham Lane, Leading Cross Green, Lenham, Maidstone, Kent, ME17 2LR	South-East Water Limited	306 mg/l	122.53 mg/l	21.44°C	30.56°F	17.12°dH	Very Hard	<a href="#">Lenham Water Quality Report</a>
ZAWIN005	Heybridge WSZ	Heybridge North Gardens, Maypole Road, Heybridge, Maldon, Essex, CM9 4SY	Northumbrian Water Limited (Essex and Suffolk)	302.85 mg/l	105.61 mg/l	21.08°C	30.29°F	17.20°dH	Very Hard	<a href="#">Heybridge Water Quality Report</a>
ZAWIN011	Pomeroy Place WSZ	Myrtlebury Way, Pilton, Exeter, EX1 3GD	South West Water Limited	83 mg/l	33 mg/l	6°C	8°F	5°dH	Soft	<a href="#">Pomeroy Place Water Quality Report</a>
ZAWIN013	Beaulieu Park WSZ	Greater Beaulieu Park, White Hart Lane, Springfield, Chelmsford, CM1 6FU	Northumbrian Water Limited (Essex and Suffolk)	297.50 mg/l	105.91 mg/l	20.66°C	29.69°F	16.86°dH	Hard	<a href="#">Beaulieu Park Incoming Water Quality Report</a>
ZAWIN024	Ashmead Drive WSZ	Land off Ashmead Drive, Gotherington, Tewksebury, Gloucestershire GL52 9HD	Severn Trent Water Limited	154.60 mg/l	61.84 mg/l	10.82°C	15.46°F	8.66°dH	Moderately Hard	<a href="#">Ashmead Drive WSZ Water Quality Report</a>